

**DELHI TRANSCO LTD.
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)**

Dy. G. M. (System Operation)
33kV Grid Sub-Station Building
Minto Road, New Delhi-110002
Ph. No.23221064, 23221175
Fax No. 23221012, 23221059

No. F.DTL/207/2013-14/DGM(SO)/

To

DATE 21.11.2014


1. Managing Director (IPGCL)
2. Managing Director (PPCL)
3. CEO TPDDL
4. G.M.(GT)
5. G.M.(PPCL)

Sub. : Open Cycle Certification for GT , PPCL & BAWANA for APR'14, MAY'14 & JUNE'14

Sir,

Please find herewith with the Statement of Open Cycle Certification of GT , PPCL& BAWANA for the period APR'14 to JUNE'14 for further necessary action please.

. Yours faithfully



Dy. G. M. (System Operation)

Encl : As above

Copy for favour of kind information to:
Secretary, DERC
Director (Operations), DTL
General Manager (SLDC)
Chair Person (DPPG)
CEO, BSES Rajdhani Power Ltd.
CEO, BSES Yamuna Power Ltd.
Dy. General Manager (SCADA)

DELHI TRANSCO LTD.

Certification of Open Cycle Generation of GTPS , PPCL , BAWANA & RITHALA generating stations

(All Fig. in Mus)

A) Gas Turbine

Month	Total Genera in Mus	Open Cycle Claimed in Mu	Open Cycle Certified in Mus	Certified %
APR'14	74.384204	0.674009	0.653622	0.88
MAY'14	88.116826	1.577120	1.414637	1.61
JUNE'14	94.729640	9.600500	8.838123	9.33

B) PPCL

Month	Total Genera in Mus	Open Cycle Claimed in Mu	Open Cycle Certified in Mus	Certified %
APR'14	108.52302	34.122671	33.725551	31.08
MAY'14	83.944086	41.418682	41.012259	48.86
JUNE'14	135.800304	1.190072	1.018148	0.75

C) PRAGATI III,BAWANA

Month	Total Genera in Mus	Open Cycle Claimed in Mu	Open Cycle Certified in Mus	Certified %
APR'14	2.083967	0.333465	0.250868	12.04
MAY'14	44.946318	0.297095	0.226975	0.50
JUNE'14	157.115324	0.903912	0.642314	0.41

MANAGER(SO/EA)